

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7120-1596:101

Page 1 of 1

CATEGORY: Annunciators

LISTEE: MORLEY-IAS Fire Systems, Pittway Systems Technology Group Europe Ltd, Charles Avenue, Burgess Hill West Sussex, UK RH15 9UF
Contact: David Wilson +44 1226 734012 FAX +44 1226 730997

DESIGN: Models ZXR4B-UL and ZXR5B-UL remote annunciators. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: Input 21.5 – 25.5 VDC
Model ZXR5B-UL, Supervised at FACP

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances, and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as remote annunciators for use with separately listed fire alarm control units, Models ZXa-UL and ZXe-UL (CSFM Listing No. 7165-1596:100). Refer to listee's Installation Instructions Manual for details.

2-06-2003KK



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JULY 30, 2003**

*Listing Expires **June 30, 2004***

Authorized By: **DIANE K. AREND**, Senior Deputy
Program Manager